



TRANSMISSION CORPORATION OF ANDHRA PRADESH LIMITED

From:
Chief Engineer
Construction-I
APTRANSCO
Vidyut Soudha,
Hyderabad.

To
M/s Jeevaka Industries Private Limited,
Sy No.145/1,145/11,145/3,
Chegunta, Gajwel,
Medak Dist.

Lr No:CPT 320/SE/PM-I/M/sJIPL/D.No. 1150 /2013, Dt. 26 .09.2013.

Sir,

Sub:- Supply of Transmission line and SS tower angles – Rerolling unit of M/s Jeevaka Industries Private Limited – Approval - Communicated – Regarding.

Ref:- Your letter dated 31.07.2013.

With reference to your letter cited above M/s Jeevaka Industries Private Limited is approved as a re-roller for manufacturing and supply of ISA 65X65 to ISA 200X200 of various thicknesses and channels and beams to AP Transco Projects of 132kV & 220kV Lines & Substations subject to fulfilling the following.

- 1) M/s Jeevaka Industries Private Limited shall procure steel billets/blooms from SAIL, VSP, TISCO and IISCO and other Power Grid and AP Transco approved agencies only.
- 2) The testing of angles also essential at 3rd party labs and cost to be born by M/s Jeevaka Industries Private Limited.
- 3) M/s Jeevaka Industries Private Limited should submit Bank Guarantee for Rs.10.0 Lacs and valid for 2 years with claim period of 6 months towards performance & quality assurance of materials supplied.
- 4) Materials such as angles, channels and beams rerolled for APTRANSCO should be embossed as DIIL-APT.
- 5) M/s Jeevaka Industries Private Limited should get the approval of manufacturing quality assurance plan for raw materials & steel angles before taking up rerolling of any angles for APTRANSCO projects.

Yours faithfully,


CHIEF ENGINEER
CONSTRUCTION-I

Copy to: SE/PM-I/Construction/APTRANSCO/VS
CE/Construction-II/ APTRANSCO/VS
CE/LIS/APTRANSCO/VS
CE/400kV/Construction/APTRANSCO/VS